

Notes:

- 1. The water service shall extend perpendicular to street center line except in cul—de—sacs. The tap shall be at least 24" from any adjacent joint for service.
- 2. Meter (cubic feet register) to be set for curbside reading.
- 3. A traffic load rating cover shall be used in areas without curb, in areas with rolled curb, or where the meter is located within 7 feet of the BCR, ECR or a driveway approach.
- 4. Angle meter stops shall be provided with 360° tee head rotation.
- 5. Meter boxes shall be a minimum of 6" clear from adjacent meter boxes, and 12" clear of top of "X" of driveway approaches and sidewalk access ramp.
- 6. Refer to Standard Drawing 410 and 412 for list of approved manufacturers and materials.
- 7. Manifold to be located in landscaped areas only. No concrete or asphalt cover allowed.
- 8. The applicant must demonstrate that the existing water services has the capacity to service both the existing single family dwelling and the proposed accessory dwelling unit per the California Plumbing Code.
- 9. Use of compression tee shall be for copper or poly services only. If existing service is galvanized, the galvanized line must be removed and replaced with copper pipe per existing Norco standards.

REVISED DATE 05-06-21	CITY OF NORCO PUBLIC WORKS DEPARTMENT - WATER UTILITY	DRAWNVS DATE _04-26-23
	ADU WATER SERVICE MANIFOLD	STD. NO.
		414
	APPROVED DIRECTOR OF PUBLIC WORKS	2 of 2